City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Sep 15, 2022 Inspection Result: PARTIAL PASS

Permit Number: E-21-0066

Property Address: 3303 8TH AVE SE

Contractor: RW SCOTT CONSTRUCTION CO. < NO STREET ADDRESS > AUBURN,

WA 98001 RW SCOTT CONSTRUCTION CO. < NO STREET ADDRESS>

AUBURN, WA 98001

To construct: SEWER EXTENSION

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Monument has been sealed.

Corrections:

- 1 Punch List "A"
 - 1. Finish sewer main install and all applicable aspects related.
 - 2. Stabilize area near ditch where SS c/o was placed.
 - 3. Sewer and all other corrections and/or AoF must be in place/corrected for E-21-0440 prior to this permits final acceptance.
 - 4. Remove asphalt/cold mix from stock pile area.
 - 5. Grade out stock pile area to maintain flow away from ditch and stabilize.
 - *Stabilization should consist of seed and 2" thick straw or hydroseed and 2" thick straw. Punch List "B"
 - 1. If sewer main is not going to be finished prior to occupancy an AoF should be taken.
 - 2. Need an AoF for as-builts.


Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org



Jason Little Engineering Tech IV JLittle@PuyallupWA.gov (253) 435-3636