



City of Puyallup
Building Division
333 S. Meridian, Puyallup, WA 98371
(253) 864-4165
www.cityofpuyallup.org

Comment Notice

Permit Application # PRCTI20220811

September 16, 2022

The City has completed the review of the above-mentioned permit submittal. Below please find the permit submittal review comments from your review team. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

Building Review (Reviewed By: David Leahy, (253)435-3618, DLeahy@PuyallupWA.gov)

- ◆ All pages submitted from the Architect of record need to be stamped with the Architects seal and signed. Note on page A001.
- ◆ Since now there is work being done on the first floor also the valuation would be different than the original and needs to be updated. Note on page A001.
- ◆ Provide complete sets of plans a revision-form/submittal form along with a response letter showing how all comments were addressed. The markup plans are available in the Portal with comment letter.
- ◆ Need to define how the remaining soffit is being supported. This has been a question from the field inspectors also. Page 2-22. of plans.
- ◆ Should make sure all your architectural stamps are flattened as this one is not and could be moved or possibly altered or copied which we would not want to happen. Page 1-1 of plans.
- ◆ Define how the carpet being installed complies with ICC A117.1-2009 section 302. Page 2-11 of plans.
- ◆ We do not do delegated or deferred submittals for these types of permits but would be by separate permits. Page A001 of plans.

To resubmit, you must address all comments and complete the [resubmittal form](#).

When you are ready to resubmit, you can do so using the customer portal, by **uploading a "new version" of the submittal requirement**. In addition, if any resubmittal fees have been assessed, **you will need to pay your resubmittal fee at the time of resubmittal**. **Your resubmittal will not be processed until the fee has been paid**. Please note, partial resubmittals will be deemed incomplete and returned.

The review team may have also added conditions to the permit application that are not listed above. The permit conditions can be found in the CityView portal. Please note, some of the conditions may need to be resolved prior to permit issuance.

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,
City of Puyallup Permit Center
(253) 864-4165 option 1



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

permitcenter@puyallupwa.gov