



# Hydraulic Overview

Job Number: 9898535  
Report Description: Light Hazard

Job		
Job Number 9898535	Design Engineer JOHN SOMMER	
Job Name: GOOD SAMARITAN HOSPITAL - ER DOOR TI	Phone	FAX
Address 1 401 15TH AVE SE	State Certification/License Number MCKINCL942DW	
Address 2 PUYALLUP, WA 98372	AHJ CITY OF PUYALLUP	
Address 3	Job Site/Building	

System	
Density 0.10gpm/ft <sup>2</sup>	Area of Application 1500ft <sup>2</sup> (Actual 394ft <sup>2</sup> )
Most Demanding Sprinkler Data 5.6 K-Factor 14.82 at 7.000	Hose Streams 100.00
Coverage Per Sprinkler 120ft <sup>2</sup>	Number Of Sprinklers Calculated 5 CORRIDOR CALC
System Pressure Demand 18.801	System Flow Demand 76.22
Total Demand 176.22 @ 18.801	Pressure Result +171.979 (90.1%)

Supplies					
Node	Name	Flow(gpm)	Hose Flow(gpm)	Static(psi)	Residual(psi)
1	Water Supply	400.00	100.00	193.470	181.210

Check Point Gauges			
Identifier	Pressure(psi)	K-Factor(K)	Flow(gpm)

**WASHINGTON STATE  
CERTIFICATE OF COMPETENCY  
FIRE PROTECTION SPRINKLER SYSTEMS**

Rory C. Leckband  
3514-0419-C Level 3  
McKinstry Company, L.L.C.  
MCKINCL942DW


Digitally signed by Rory C. Leckband  
DN: C=US, E=Rory.L@McKinstry.com, O=McKinstry Co., LLC, OU=Fire Protection,  
CN=Rory C. Leckband  
Location: 5005 3RD AVE S, SEATTLE, WA 98134  
Reason: I have reviewed this document.  
Contact Info: (206) 552-3189  
Date: 2022.08.26 16:32:19-0700

**Signature** *Rory C. Leckband* **Date** **Expires 12/31/21**

Water Supply at Node 1 (400.00, 0.00, 193.470, 181.210)

**City of Puyallup  
Development & Permitting Services  
ISSUED PERMIT**

Building	Planning
Engineering	Public Works
Fire	Traffic




<b>Gauge</b>	<b>Flow(gpm)</b>	<b>Inlet Static Pressure(psi)</b>	<b>Inlet Residual Pressure(psi)</b>	<b>Elevation(Foot)</b>
System 1-1	400	193.47	181.21	134'-2
System 1-2	400	186.96	174.31	149'-2
System 1-3	400	179.59	166.63	166'-2
System 1-4	400	172.66	159.11	182'-2
System 1-5	400	163.99	150.13	202'-2
System 1-6	400	157.49	143.55	217'-2
System 1-7	400	150.987	136.97	232'-2
System 1-8	400	144.484	130.39	247'-2
System 2-A	400	199.39	184.5	120'-0
System 2-1	400	193.54	178.44	134'-0
System 2-2	400	187.04	171.54	149'-0
System 2-3	400	179.66	163.89	166'-0
System 2-4	400	172.73	156.68	182'-0
System 2-5	400	164.06	147.7	202'-0
System 2-6	400	157.56	141.12	217'-0
System 2-7	400	151.06	134.54	232'-0
System 2-8	400	144.55	127.96	247'-0





### Water Supply at Node 1



Hydraulic Graph

#### Water Supply at Node 1

Static: Pressure  
193.470

Residual: Pressure  
181.210 @ 400.00

Available Pressure at System Demand  
190.779 @ 176.22

Required Pressure at System Demand  
18.801 @ 76.22

Required Pressure at System Demand (Including Hose Allowance at Source)  
18.801 @ 176.22



# Summary Of Outflowing Devices

Job Number: 9898535  
Report Description: Light Hazard

Device		Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)		
⇒ Sprinkler	101	14.82	12.00	5.6	7.000		
Sprinkler	102	14.82	12.00	5.6	7.000		
Sprinkler	103	15.73	12.00	5.6	7.893		
Sprinkler	104	15.48	12.00	5.6	7.642		
Sprinkler	105	15.38	12.00	5.6	7.541		

⇒ Most Demanding Sprinkler Data



# Node Analysis

Job Number: 9898535  
Report Description: Light Hazard

Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
1	135'-0	S	18.801	76.22
101	139'-9	Spr(-7.000), fd(22'-0)	7.000	14.82
102	139'-9	Spr(-7.000), fd(22'-0)	7.000	14.82
103	139'-9	Spr(-7.893), fd(22'-0)	7.893	15.73
104	139'-9	Spr(-7.642), fd(22'-0)	7.642	15.48
105	139'-9	Spr(-7.541), fd(22'-0)	7.541	15.38
5	143'-9½	PO(8'-8½)	12.955	
18	136'-8		17.602	
22	137'-9		17.114	
39	140'-6	T(5'-0)	8.692	
40	143'-9½	T(5'-0)	9.498	
44	143'-9½	T(5'-0)	8.836	
47	143'-9½	T(5'-0)	8.506	
50	143'-9½	T(5'-0)	8.373	



# Hydraulic Analysis

Job Number: 9898535  
Report Description: Light Hazard

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Fittings	Eq. Length	Summary
Upstream				Pn		Total Length	
<b>Route 1</b>							
DY	1.0490	14.82	5.50	120	0.074703	0'-0"	Pf 2.017
102	139'-9"	14.82	5.6	7.000	Sprinkler,	27'-0"	Pe -0.325
39	140'-6"			8.692	T(5'-0), fd(22'-0)	27'-0"	Pv
BL	1.0490	29.63	11.00	120	0.269306	3'-3½"	Pf 2.233
39	140'-6"	14.82		8.692	Flow (q) from Route 2	5'-0"	Pe -1.427
40	143'-9½"			9.498	T(5'-0)	8'-3½"	Pv
BL	1.6390	76.22	11.59	120	0.176003	10'-11"	Pf 3.457
40	143'-9½"	46.59		9.498	Flow (q) from Route 3	8'-8½"	Pe
5	143'-9½"			12.955	PO(8'-8½)	19'-7½"	Pv
CM	2.7030	76.22	4.26	120	0.015397	56'-0½"	Pf 1.540
5	143'-9½"			12.955		44'-0"	Pe 2.619
22	137'-9"			17.114	2PO(18'-8), fE(6'-8)	100'-0"	Pv
MS	2.6350	76.22	4.48	120	0.017431	1'-1"	Pf 0.019
22	137'-9"			17.114			Pe 0.470
18	136'-8"			17.602	2f(-0.000)	1'-1"	Pv
BL	2.7030	76.22	4.26	120	0.015397	2'-11"	Pf 0.476
18	136'-8"			17.602		27'-11½"	Pe 0.723
1	135'-0"			18.801	3E(9'-4), S	30'-11"	Pv
		100.00			Hose Allowance At Source		
1		176.22					
<b>Route 2</b>							
DY	1.0490	14.82	5.50	120	0.074703	0'-0"	Pf 2.017
101	139'-9"	14.82	5.6	7.000	Sprinkler,	27'-0"	Pe -0.325
39	140'-6"			8.692	T(5'-0), fd(22'-0)	27'-0"	Pv
<b>Route 3</b>							
BL	1.0490	15.38	5.71	120	0.080027	3'-3½"	Pf 2.584
105	139'-9"	15.38	5.6	7.541	Sprinkler,	29'-0"	Pe -1.752
50	143'-9½"			8.373	E(2'-0), T(5'-0), fd(22'-0)	32'-3½"	Pv
BL	1.6390	15.38	2.34	120	0.009108	14'-7½"	Pf 0.133
50	143'-9½"			8.373			Pe
47	143'-9½"			8.506		14'-7½"	Pv
BL	1.6390	30.86	4.69	120	0.033037	10'-0"	Pf 0.330
47	143'-9½"	15.48		8.506	Flow (q) from Route 4		Pe
44	143'-9½"			8.836		10'-0"	Pv
BL	1.6390	46.59	7.08	120	0.070798	9'-4"	Pf 0.661
44	143'-9½"	15.73		8.836	Flow (q) from Route 5		Pe
40	143'-9½"			9.498		9'-4"	Pv
<b>Route 4</b>							
BL	1.0490	15.48	5.75	120	0.081019	3'-3½"	Pf 2.616
104	139'-9"	15.48	5.6	7.642	Sprinkler,	29'-0"	Pe -1.752
47	143'-9½"			8.506	E(2'-0), T(5'-0), fd(22'-0)	32'-3½"	Pv
<b>Route 5</b>							
BL	1.0490	15.73	5.84	120	0.083477	3'-3½"	Pf 2.696
103	139'-9"	15.73	5.6	7.893	Sprinkler,	29'-0"	Pe -1.752
44	143'-9½"			8.836	E(2'-0), T(5'-0), fd(22'-0)	32'-3½"	Pv

### Equivalent Pipe Lengths of Valves and Fittings (C=120 only)

$$\left( \frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

### C Value Multiplier

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51



# Hydraulic Analysis

Job Number: 9898535

Report Description: Light Hazard

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss		Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Fittings	Eq. Length	Summary
Upstream							Total Length	

Pipe Type Legend	
AO	Arm-Over
BL	Branch Line
CM	Cross Main
DN	Drain
DR	Drop
DY	Dynamic
FM	Feed Main
FR	Feed Riser
MS	Miscellaneous
OR	Outrigger
RN	Riser Nipple
SP	Sprig
ST	Stand Pipe
UG	Underground

Units Legend	
Diameter	Inch
Elevation	Foot
Flow	gpm
Discharge	gpm
Velocity	fps
Pressure	psi
Length	Foot
Friction Loss	psi/Foot
HWC	Hazen-Williams Constant
Pt	Total pressure at a point in a pipe
Pn	Normal pressure at a point in a pipe
Pf	Pressure loss due to friction between points
Pe	Pressure due to elevation difference between indicated points
Pv	Velocity pressure at a point in a pipe

Fittings Legend	
ALV	Alarm Valve
AngV	Angle Valve
b	Bushing
BalV	Ball Valve
BFP	Backflow Preventer
BV	Butterfly Valve
C	Cross Flow Turn 90°
cplg	Coupling
Cr	Cross Run
CV	Check Valve
DeV	Deluge Valve
DPV	Dry Pipe Valve
E	90° Elbow
EE	45° Elbow
Ee1	11¼° Elbow
Ee2	22½° Elbow
f	Flow Device
fd	Flex Drop
FDC	Fire Department Connection
fE	90° FireLock(TM) Elbow
fEE	45° FireLock(TM) Elbow
flg	Flange
FN	Floating Node
fT	FireLock(TM) Tee
g	Gauge
GloV	Globe Valve
GV	Gate Valve
Ho	Hose
Hose	Hose
HV	Hose Valve
Hyd	Hydrant
LtE	Long Turn Elbow
mecT	Mechanical Tee
Noz	Nozzle
P1	Pump In
P2	Pump Out
PIV	Post Indicating Valve
PO	Pipe Outlet
PRV	Pressure Reducing Valve
PrV	Pressure Relief Valve
red	Reducer/Adapter
S	Supply
sCV	Swing Check Valve
Spr	Sprinkler
St	Strainer
T	Tee Flow Turn 90°
Tr	Tee Run
U	Union
WirF	Wirsbo
WMV	Water Meter Valve
Z	Cap