



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

# Comment Notice

**Permit Application # PRCTI20221271**

September 19, 2022

The City has completed the review of the above-mentioned permit submittal. Below please find the permit submittal review comments from your review team. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

**Building Review** (Reviewed By: David Leahy, (253)435-3618, [DLeahy@PuyallupWA.gov](mailto:DLeahy@PuyallupWA.gov))

- ♦ Would not be per the King County assessors office for this project. Page CS1.1 of plans.
- ♦ Define the height of all vision lites to show compliance to ICC A117.1-2009 section 404.2.10. Page ID-5.1 of plans.
- ♦ Define the amount of deflection required and show it in this detail. Page ID-5.1, detail 2 of plans.
- ♦ Define size of grill and what this line is for on the plans. Page M2.01 of plans.
- ♦ Define how these walls are to be secured to the floor on the plans. Page ID-5.1 detail 2.
- ♦ This is indicating a Fire Resistive wall so show the actual rating and an approved assembly on the plans. Page ID-5.1 detail 2 of plans.

To resubmit, you must address all comments and complete the [resubmittal form](#).

When you are ready to resubmit, you can do so using the customer portal, by **uploading a “new version” of the submittal requirement**. In addition, if any resubmittal fees have been assessed, **you will need to pay your resubmittal fee at the time of resubmittal**. **Your resubmittal will not be processed until the fee has been paid**. Please note, partial resubmittals will be deemed incomplete and returned.

The review team may have also added conditions to the permit application that are not listed above. The permit conditions can be found in the CityView portal. Please note, some of the conditions may need to be resolved prior to permit issuance.

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center

(253) 864-4165 option 1

[permitcenter@puyallupwa.gov](mailto:permitcenter@puyallupwa.gov)