

**DAILY FIELD REPORT****AAR TESTING AND INSPECTION, INC.**

7126 180th Ave NE, Suite C101
Redmond, WA 98052
425-881-5812

Reviewed 9/14/2022 DL Subject to field
inspectors approvals.

Inspection Date
07/01/2022

Report Number
Mpt070122B

CLIENT INFORMATION		PROJECT INFORMATION	
Contact	Amy	Project No.	22-412
Company	ATSCo	Project Name	Boar's Head Seattle
Address	1760 Britannia Drive, Suite 4	Address	402 Valley Avenue NW, Suite 105
City	Elgin, IL	City	Puyallup
Contractor		Permit No.	59848

INSPECTION TYPE(S)	STRUCTURE(S) / LOCATION(S)
☒ Proprietary Anchors - Mechanical	Freezer pallet racks

Weather	Temperature (°F)	Start Time	End Time
---------	------------------	------------	----------

DRAWINGS / DOCUMENTS REFERENCED


INSPECTION OBSERVATION / REMARKS

Verified installation of DeWalt Power SD anchors 1/2"/4.5" with 3.25" embed torqued to 50 ft lbs All Installed Per ESR 2818

☒ Items inspected are in conformance with approved plans, specifications and jurisdictional requirements

THIS REPORT AND INSPECTIONS WERE DONE PRIOR TO HAVING
ANY APPROVED PLANS FOR THE RACKS. SUBJECT TO CITY
INSPECTOR'S ACCEPTANCE.

IF THESE ANCHORS WERE ONLY TORQUE TESTED THEN
VERIFY THEY WERE INSPECTED DURING THE INSTALLATION
PER THE ESR REPORT SUBMITTED.



Inspectors Signature	Inspectors Name	Report Date	Reviewers Signature	Reviewed By	Reviewed Date
	Michael Trow	07/01/2022		Teajalam (TJ) Gouden	

89343438-A852-48E7-B724-30C405C079AF



DAILY FIELD REPORT


AAR TESTING AND INSPECTION, INC.

7126 180th Ave NE, Suite C101
Redmond, WA 98052
425-881-5812

Inspection Date
07/01/2022

Report Number
Mpt070122B

PHOTOS



Inspectors Signature

Inspectors Name
Michael Trow

Report Date
07/01/2022

Reviewers Signature

Reviewed By
Teajalam (TJ) Gounden

Reviewed Date

89343438-A852-48E7-B724-30C405C079AF