

FIRE PROTECTION HYDRAULIC CALCUTIONS

BODY HOLDING

GOOD SAMARITAN HOSPITAL

401 15th AVE SE
PUYALLUP, WA 98372

JOB NUMBER: 122775-001

SUBMITTED BY: BROOKE McDANIELS

City of Puyallup Development & Permitting Services ISSUED PERMIT	
Building	Planning
Engineering	Public Works
Fire	Traffic

**WASHINGTON STATE
CERTIFICATE OF COMPETENCY
FIRE PROTECTION SPRINKLER SYSTEMS**

Rory C. Leckband
3514-0419-C Level 3
McKinstry Company, L.L.C.
MCKINCL942DW

Digitally signed by Rory C. Leckband
DN: C=US, E=RoryL@McKinstry.com, O=McKinstry Co., LLC, OU=Fire Protection,
CN=Rory C. Leckband
Locality: 5005 3RD AVE S, SEATTLE, WA 98134
Reason: I have reviewed this document
Contact Info: (206) 552-3189
Date: 2022.09.09 06:06:16 -0700

Rory C. Leckband
Signature **Date** **Expires**
12/31/21



Seattle:
5005 3rd Avenue South
Seattle, WA 98124
206.762.3311

Portland:
400 NE Columbia Blvd.
Portland, OR 97218
503.331.0234

Spokane:
850 E Spokane Falls Blvd.
Spokane, WA 99202
509.747.3389



Hydraulic Overview

Job Number: 122775-001
Report Description: Ordinary Group II

Job	
Job Number 122775-001	Design Engineer BROOKE McDANIELS
Job Name: BODY HOLDING	Phone 360-912-9183
Address 1 GOOD SAMARITAN HOSPITAL	State Certification/License Number MCKINCL942DW
Address 2 401 15TH AVE SE	AHJ CITY OF PUYALLUP
Address 3 PUYALLUP, WA 98372	Job Site/Building GOOD SAMARITAN HOSPITAL



System	
Density 0.20gpm/ft ²	Area of Application 1500ft ² (Actual 352ft ²)
Most Demanding Sprinkler Data 5.6 K-Factor 36.00 at 41.327	Hose Streams 250.00
Coverage Per Sprinkler 120ft ²	Number Of Sprinklers Calculated 6
System Pressure Demand 63.970	System Flow Demand 220.15
Total Demand 470.15 @ 63.970	Pressure Result +18.767 (22.7%)

Supplies						Check Point Gauges			
<u>Node</u>	<u>Name</u>	<u>Flow(gpm)</u>	<u>Hose Flow(gpm)</u>	<u>Static(psi)</u>	<u>Residual(psi)</u>	<u>Identifier</u>	<u>Pressure(psi)</u>	<u>K-Factor(K)</u>	<u>Flow(gpm)</u>
1	Water Supply	350.00	250.00	100.000	90.000				

City of Puyallup
Development & Permitting Services
ISSUED PERMIT

Building	Planning
Engineering	Public Works
Fire	Traffic

122775 GSH Body Holding Water Supply at Node 1 (350.00, 0.00, 100.000, 90.000)





Hydraulic Summary

Job Number: 122775-001
Report Description: Ordinary Group II

Job	
Job Number 122775-001	Design Engineer BROOKE McDANIELS
Job Name: BODY HOLDING	State Certification/License Number MCKINCL942DW
Address 1 GOOD SAMARITAN HOSPITAL	AHJ CITY OF PUYALLUP
Address 2 401 15TH AVE SE	Job Site/Building GOOD SAMARITAN HOSPITAL
Address 3 PUYALLUP, WA 98372	Drawing Name 122775 GSH Body Holding


System		Remote Area(s)	
Most Demanding Sprinkler Data 5.6 K-Factor 36.00 at 41.327		Occupancy Ordinary Group II	Job Suffix
Hose Allowance At Source 250.00		Density 0.20gpm/ft ²	Area of Application 1500ft ² (Actual 352ft ²)
Additional Hose Supplies <u>Node</u> <u>Flow(gpm)</u>		Number Of Sprinklers Calculated 6	Number Of Nozzles Calculated 0
		Coverage Per Sprinkler 120ft ²	
		AutoPeak Results: Pressure For Remote Area(s) Adjacent To Most Remote Area Left: 63.970 Right: 63.970	
Total Hose Streams 250.00			
System Flow Demand 220.15	Total Water Required (Including Hose Allowance) 470.15		
Maximum Pressure Unbalance In Loops 0.000			
Maximum Velocity Above Ground 27.25 between nodes 7 and 9			
Maximum Velocity Under Ground			
Volume capacity of Wet Pipes 228.38gal	Volume capacity of Dry Pipes		

Supplies									
Node	Name	Hose Flow (gpm)	Static (psi)	Residual (psi) @	Flow (gpm)	Available (psi) @	Total Demand (gpm)	Required (psi)	Safety Margin (psi)
1	Water Supply	250.00	100.000	90.000 @	350.00	82.737 @	470.15	63.970	18.767

Contractor			
Contractor Number MCKINCL942DW		Contact Name BROOKE McDANIELS	
Name of Contractor: McKINSTRY FIRE PROTECTION		Contact Title DESIGNER	
Address 1 5005 3RD AVENUE S		Phone 360-912-9183	
Address 2 SEATTLE, WA 98124		FAX	
Address 3		E-mail BROOKEM@MCKINSTRY.COM	
		Web-Site	



Water Supply at Node 1



Hydraulic Graph
Water Supply at Node 1

Static: Pressure
100.000

Residual: Pressure
90.000 @ 350.00

Available Pressure at System Demand
82.737 @ 470.15

Required Pressure at System Demand
63.970 @ 220.15

Required Pressure at System Demand (Including Hose Allowance at Source)
63.970 @ 470.15

City of Puyallup
Development & Permitting Services
ISSUED PERMIT

Building	Planning
Engineering	Public Works
Fire	Traffic



Summary Of Outflowing Devices

Device		Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)		
Sprinkler	100	37.39	36.00	5.6	44.572		
Sprinkler	101	36.01	36.00	5.6	41.357		
Sprinkler	102	37.38	36.00	5.6	44.547		
Sprinkler	103	36.00	36.00	5.6	41.333		
Sprinkler	104	37.37	36.00	5.6	44.540		
⇒ Sprinkler	105	36.00	36.00	5.6	41.327		

⇒ Most Demanding Sprinkler Data

City of Puyallup
Development & Permitting Services
ISSUED PERMIT

Building	Planning
Engineering	Public Works
Fire	Traffic



Node Analysis

Job Number: 122775-001
Report Description: Ordinary Group II

Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
1	3'-1½	S	63.970	220.15
100	8'-0	Spr(-44.572)	44.572	37.39
101	8'-0	Spr(-41.357)	41.357	36.01
102	8'-0	Spr(-44.547)	44.547	37.38
103	8'-0	Spr(-41.333)	41.333	36.00
104	8'-0	Spr(-44.540)	44.540	37.37
105	8'-0	Spr(-41.327)	41.327	36.00
5	10'-6	E(13'-2)	60.590	
6	10'-6	PO(8'-0)	58.842	
7	11'-0	E(2'-0)	57.104	
8	10'-6	PO(8'-0)	58.808	
9	11'-0	T(5'-0)	49.627	
10	11'-0	E(2'-0)	57.071	
11	11'-0	T(5'-0)	49.597	
12	10'-6	PO(8'-0)	58.799	
13	11'-0	E(2'-0)	57.061	
14	11'-0	T(5'-0)	49.589	

City of Puyallup
Development & Permitting Services
ISSUED PERMIT

Building	Planning
Engineering	Public Works
Fire	Traffic



Hydraulic Analysis

Job Number: 122775-001
Report Description: Ordinary Group II

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Fittings	Eq. Length	Summary
Upstream				Pn		Total Length	
Route 1							
DR	1.0490	36.00	13.36	120	0.386043	15'-9½"	Pf 9.563
105	8'-0"	36.00	5.6	41.327	Sprinkler,	9'-0"	Pe -1.301
14	11'-0"			49.589	2E(2'-0), T(5'-0)	24'-9½"	Pv
BL	1.0490	73.37	27.24	120	1.441191	3'-2"	Pf 7.472
14	11'-0"	37.37		49.589	Flow (q) from Route 4	2'-0"	Pe
13	11'-0"			57.061	E(2'-0)	5'-2"	Pv
BL	1.6100	73.37	11.56	120	0.178919	0'-6"	Pf 1.521
13	11'-0"			57.061		8'-0"	Pe 0.217
12	10'-6"			58.799	PO(8'-0)	8'-6"	Pv
BL	4.2600	73.37	1.65	120	0.001566	6'-0"	Pf 0.009
12	10'-6"			58.799			Pe
8	10'-6"			58.808		6'-0"	Pv
BL	4.2600	146.75	3.30	120	0.005644	6'-0"	Pf 0.034
8	10'-6"	73.38		58.808	Flow (q) from Route 2		Pe
6	10'-6"			58.842		6'-0"	Pv
BL	4.2600	220.15	4.96	120	0.011953	106'-8½"	Pf 1.747
6	10'-6"	73.40		58.842	Flow (q) from Route 3	39'-6"	Pe
5	10'-6"			60.590	3E(13'-2)	146'-2½"	Pv
BL	6.3570	220.15	2.23	120	0.001702	59'-6"	Pf 0.183
5	10'-6"			60.590		47'-9½"	Pe 3.198
1	3'-1½"			63.970	2E(17'-7), BV(12'-7), S	107'-3½"	Pv
		250.00			Hose Allowance At Source		
1		470.15					
Route 2							
DR	1.0490	36.00	13.37	120	0.386101	15'-9½"	Pf 9.565
103	8'-0"	36.00	5.6	41.333	Sprinkler,	9'-0"	Pe -1.301
11	11'-0"			49.597	2E(2'-0), T(5'-0)	24'-9½"	Pv
BL	1.0490	73.38	27.24	120	1.441407	3'-2"	Pf 7.473
11	11'-0"	37.38		49.597	Flow (q) from Route 5	2'-0"	Pe
10	11'-0"			57.071	E(2'-0)	5'-2"	Pv
BL	1.6100	73.38	11.56	120	0.178946	0'-6"	Pf 1.521
10	11'-0"			57.071		8'-0"	Pe 0.217
8	10'-6"			58.808	PO(8'-0)	8'-6"	Pv
Route 3							
DR	1.0490	36.01	13.37	120	0.386304	15'-9½"	Pf 9.571
101	8'-0"	36.01	5.6	41.357	Sprinkler,	9'-0"	Pe -1.301
9	11'-0"			49.627	2E(2'-0), T(5'-0)	24'-9½"	Pv
BL	1.0490	73.40	27.25	120	1.442162	3'-2"	Pf 7.477
9	11'-0"	37.39		49.627	Flow (q) from Route 6	2'-0"	Pe
7	11'-0"			57.104	E(2'-0)	5'-2"	Pv
BL	1.6100	73.40	11.57	120	0.179039	0'-6"	Pf 1.522
7	11'-0"			57.104		8'-0"	Pe 0.217
6	10'-6"			58.842	PO(8'-0)	8'-6"	Pv
Route 4							
DR	1.0490	37.37	13.87	120	0.413727	6'-4"	Pf 6.350
104	8'-0"	37.37	5.6	44.540	Sprinkler,	9'-0"	Pe -1.301
14	11'-0"			49.589	2E(2'-0), T(5'-0)	15'-4"	Pv
Route 5							
DR	1.0490	37.38	13.88	120	0.413789	6'-4"	Pf 6.351
102	8'-0"	37.38	5.6	44.547	Sprinkler,	9'-0"	Pe -1.301
11	11'-0"			49.597	2E(2'-0), T(5'-0)	15'-4"	Pv
Route 6							
DR	1.0490	37.39	13.88	120	0.414006	6'-4"	Pf 6.355
100	8'-0"	37.39	5.6	44.572	Sprinkler,	9'-0"	Pe -1.301
9	11'-0"			49.627	2E(2'-0), T(5'-0)	15'-4"	Pv

Equivalent Pipe Lengths of Valves and Fittings (C=120 only)

C Value Multiplier

$$\left(\frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51

City of Puyallup
Development & Permitting Services
ISSUED PERMIT

Building	Planning
Engineering	Public Works
Fire	Traffic



Hydraulic Analysis

Job Number: 122775-001
Report Description: Ordinary Group II

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Eq. Length	Summary
Upstream						Total Length	

Pipe Type Legend	
AO	Arm-Over
BL	Branch Line
CM	Cross Main
DN	Drain
DR	Drop
DY	Dynamic
FM	Feed Main
FR	Feed Riser
MS	Miscellaneous
OR	Outrigger
RN	Riser Nipple
SP	Sprig
ST	Stand Pipe
UG	Underground

Units Legend	
Diameter	Inch
Elevation	Foot
Flow	gpm
Discharge	gpm
Velocity	fps
Pressure	psi
Length	Foot
Friction Loss	psi/Foot
HWC	Hazen-Williams Constant
Pt	Total pressure at a point in a pipe
Pn	Normal pressure at a point in a pipe
Pf	Pressure loss due to friction between points
Pe	Pressure due to elevation difference between indicated points
Pv	Velocity pressure at a point in a pipe

Fittings Legend	
ALV	Alarm Valve
AngV	Angle Valve
b	Bushing
BalV	Ball Valve
BFP	Backflow Preventer
BV	Butterfly Valve
C	Cross Flow Turn 90°
cplg	Coupling
Cr	Cross Run
CV	Check Valve
DeV	Deluge Valve
DPV	Dry Pipe Valve
E	90° Elbow
EE	45° Elbow
Ee1	11¼° Elbow
Ee2	22½° Elbow
f	Flow Device
fd	Flex Drop
FDC	Fire Department Connection
fE	90° FireLock(TM) Elbow
fEE	45° FireLock(TM) Elbow
flg	Flange
FN	Floating Node
fT	FireLock(TM) Tee
g	Gauge
GloV	Globe Valve
GV	Gate Valve
Ho	Hose
Hose	Hose
HV	Hose Valve
Hyd	Hydrant
LtE	Long Turn Elbow
mecT	Mechanical Tee
Noz	Nozzle
P1	Pump In
P2	Pump Out
PIV	Post Indicating Valve
PO	Pipe Outlet
PRV	Pressure Reducing Valve
PrV	Pressure Relief Valve
red	Reducer/Adapter
S	Supply
sCV	Swing Check Valve
Spr	Sprinkler
St	Strainer
T	Tee Flow Turn 90°
Tr	Tee Run
U	Union
WirF	Wirsbo
WMV	Water Meter Valve
Z	Cap

City of Puyallup
Development & Permitting Services
ISSUED PERMIT

Building	Planning
Engineering	Public Works
Fire	Traffic