



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Sep 20, 2022

Inspection Result: PASSED

Permit Number: B-21-0029

Property Address: 2505 INTER AVE ;

Contractor:

To construct: CHANGE OF USE FROM R3 TO OFFICE USE ~ PRO VAC

BLDG/PLUMB/MECH 2015 CODES

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684