



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Sep 23, 2022 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCTI20220811

Property Address: 3500 S MERIDIAN, Unit: 985, PUYALLUP, WA 98373;

Contractor: PINE RIDGE CONST MGMT LLC 1000 COMMERCE PARK DR ST 518
WILLIAMSPORT, PA 17701 (570) 505-3890 Cameron Malchow 1000
Commerce Park Drive Williamsport, PA 17701

To construct: Macy's SCOPE OF WORK CONSISTS OF INTERIOR ALTERATIONS LIMITED
TO DEMOLITION OF NON-STRUCTURAL ELEMENTS, CONSTRUCTION OF
NON-LOADBEARING PARTITIONS, MODIFICATIONS TO AFFECTED
CEILINGS, AND INSTALLATION OF SHELVING LESS THAN 5'9" AND
MILLWORK. NO CHANGE OF USE IS PROPOSED. NO CHANGES TO
BUILDING ENVELOPE. BLDG ONLY - 8/24/2022 - MISCELLANEOUS
REVISIONS TO PARTITIONS, CEILINGS AND FINISHES

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1.section 2 tiered ceiling approved
2 soffits in this area that are hard lids approved

Corrections:

- 1 1.remove flooring from under wall plates so it will bear on concrete
2.complete framing on door opening
3.complete all framing above mechanical equipment
4.complete all fasteners at studs to wall plates 5.verify that electrical J/Box in concrete are abandoned where new wall plates are placed
6. Provide architectural plans for all walls removed and demo
7. Remove all abandoned ducting, framing, electrical conduit thru out space
- 2 1 : inspection of of framing at exterior wall at s. e. corner only. (complete vapor barrier at exterior wall prior to inspection) not ready
- 3 1. provide attachment detail for this area from the architect



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

2. provide electrical cover approval prior to next inspection
3. not ready

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590