



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Sep 26, 2022

Inspection Result: NOT READY

Permit Number: PRCTI20220811

Property Address: 3500 S MERIDIAN, Unit: 985, PUYALLUP, WA 98373;

Contractor: PINE RIDGE CONST MGMT LLC 1000 COMMERCE PARK DR ST 518
WILLIAMSPORT, PA 17701 (570) 505-3890 Cameron Malchow 1000
Commerce Park Drive Williamsport, PA 17701

To construct: Macy's SCOPE OF WORK CONSISTS OF INTERIOR ALTERATIONS LIMITED
TO DEMOLITION OF NON-STRUCTURAL ELEMENTS, CONSTRUCTION OF
NON-LOADBEARING PARTITIONS, MODIFICATIONS TO AFFECTED
CEILINGS, AND INSTALLATION OF SHELVING LESS THAN 5'9" AND
MILLWORK. NO CHANGE OF USE IS PROPOSED. NO CHANGES TO
BUILDING ENVELOPE. BLDG ONLY - 8/24/2022 - MISCELLANEOUS
REVISIONS TO PARTITIONS, CEILINGS AND FINISHES

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: cancel per contractor. (not ready)

Corrections:

Sincerely,

Shannon King
Building Inspector 2



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

ShannonK@PuyallupWA.gov

(253) 840-6684