



CITY OF PUYALLUP
Development & Permitting Services
 333 S. Meridian, Puyallup, WA 98371
 (253) 864-4165
www.cityofpuyallup.org

Permit No:
 PRFA20221350

FIRE ALARMS

Puyallup, WA

Job Address	Address: 1201 39TH AVE SW, PUYALLUP, WA 98373 Parcel # 0419043114	ISSUED September 27, 2022
Owner	COSTCO WHOLESALE CORP 999 LAKE DR ISSAQUAH, WA 98027-8990	
Applicant	Jeff Bloomquist 3409 S 37th St Tacoma, WA 98409 (253) 472-2955 rich@soundelectronics.com	
Contractor	SOUND ELECTRONICS 3409 S 37TH ST TACOMA, WA 98409 WA L&I #:	
Description of Work	At the Puyallup Costco they are turning the existing breakroom in to a 2 story break / locker room.	
Permit Types	Fire Alarms	
Expiration Date:	March 26, 2023	

Building Components:

Quantity	Units	Description	Unit Cost	Subtotal Cost
13	DEVICES	Fire Alarm and Detection System and Related Equipment, Alteration	\$0.00	\$0.00
Total Value of Work:				\$0.00

Standard Conditions:

1. • Appointment required for all inspections am/pm is not guaranteed without appointment. Larger systems taking more than 1 hour will require 48-72hr notice prior to scheduling. Inspections are Monday - Thursday, no friday inspections
 - Provide plans and permit on site for inspection.
 - Complete labor and industries inspections prior to requesting city inspection.
 - Above ceiling detection is required.
 - Device maps required at the annunciator and fire alarm panel prior to calling in final. The annunciator map will need to be weatherproof.
 - Total coverage is required, subject to field inspection. Comply with NFPA 72, 2016
 - Fire alarm system shall be placarded per NFPA 72. The UL certificate shall be posted at time of final inspection. The system will need to be UL certified.
 - A pre-test shall be conducted and a printout of the location of the device, point number and descriptor shall be furnished to the inspector at final. Labeling of all devices above and below ceiling required.
 - The city of Puyallup allows one FACP per building. The panel will need to be large enough to handle multiple tenants if applicable.
 - In existing buildings all above ceiling detection is to remain. Do not remove.

- Due to unforeseeable construction design, all device locations to be field verified for compliance. Schedule your inspection online through the city of puyallup online permit system after requesting appointment from inspector. Fire Inspections are Monday – Thursday there will be no inspections on Fridays. David Drake 253-864-4171 ddrake@puyallupwa.gov

Permit is valid 180 days from date of issuance. Permit validity is subject to all adhering to all applicable codes, ordinances and standards, and conditions of this permit.

I certify that I am the owner of this property or the owner's authorized agent, including an appropriately licensed contractor. I have read and examined this application and furnished true and correct information. I will comply with all provisions of law and ordinances governing this type of construction work, whether specific herein or not. By submitting this application, I give the jurisdiction permission to enter the property to perform inspections. The granting of this permit does not presume or give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. I understand that failure to comply with the above may result in revocation of the permit.

Applicant:
Jeff Bloomquist