



A R C H I T E C T U R E

September 27, 2022

City of Puyallup Planning Division
Re: Case #: PRCTI20221271

Attn: NComstock

Below are the open items in the correction notice along with our response to each:

Would not be per the Kind County Assessors office for this project. Page CS1.1 of plans

MZA Response: Updated.

Define the amount of deflection required and show it in this detail. Page ID-5.1, detail 2 of plans.

MZA Response: Detail updated to reflect 10'-0"H partition with partition bracing to existing structure. Refer to updated detail 2 and existing detail 3 on ID-5.1.

Define how these walls are to be secured to the floor on the plans. Page ID-5.1 detail 2.

MZA Response: Detail update to reflect specific ramset low velocity fastener at 16 on center. Refer to detail 3 on ID-5.1.

This is indicating a Fire Resistive wall so show the actual rating and an approved assembly on the plans. Page ID-5.1 detail 2 of plans.

MZA Response: Partitions are not intended to be fire rated. Wall type detail fire rating updated to reflect this. Refer to detail 3 on ID-5.1.

Define the height of all vision lites to show compliance to ICC A117.1-2009 section 404.2.10. Page ID-5.1 of plans,

MZA Response: Vision lite heights called out on detail 6 and 7 on ID-5.1.

Define size of grill and what this line is for on the plans. Page M2.01 of plans.



A R C H I T E C T U R E

MZA Response: We would transition the 24"Ø to a 24"x20" opening in the t-bar with birdscreen over it for the make-up air. This line is our make-up air pathway. We will bring the air in from our 6.9 SF louver, through the 24"Ø R-7 insulated ductwork to the 24" x 24" opening in the t-bar covered with birdscreen. This will work in conjunction with our exhaust system to keep the chiller room pressure at equilibrium.

List of updates/changes by sheet number:

1. ID-0.0 Cover Sheet & Site Plan:
 - a. Legal description assessor office updated
2. ID-5.1 Wall Sections and Door Elevations and Details
 - a. Wall section updated to show:
 - i. No fire rating
 - ii. Updated attachment to structure information
 - iii. Updated attachment to floor information
 - b. Dimensions added to vision lite to show height based on ICC A117.1-2009 section 404.2.10.
3. M2.01 Partial 1st Floor Plans & Schedule – HVAC
 - a. Drawings not updated, refer to correction comment above to answer your questions.

Please let me know if you have any additional questions about the above responses.

Best regards,

Emily Evans
Emily.evans@mza-us.com 610.621.3643

MZA Architecture
1911 116th Ave NE
Bellevue, WA 98004