



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Sep 28, 2022                      **Inspection Result:**      **FAILED**

**Permit Number:** B-21-0256

**Property Address:** 3303 8TH AVE SE      ;

**Contractor:** David Douglas 7457 Tacoma, WA 98409 (253) 474-5281

**To construct:** TI ~ MODIFY BATHROOM; INCREASE KITCHEN; ADD STORAGE;  
REMOVE CLASSROOM & OFFICE. ~ STEP BY STEPBLDG/MECH/PLUMB

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** INSP FINAL COMMERCIAL - No Comments

### Corrections:

- 1 1 ; paint all gas pipe at exterior of building.
- 2 ; seal all penetrations in exterior siding.
- 3 ; insulate water supply lines at swamp coolers.
- 4 ; provide fire damper access door signage at mechanical duct on roof as discussed with contractor.
- 5 ; provide service access for removal of filter at mechanical as discussed with contractor.
- 6 ; provide positive connection of unit on roof.(Daikin)
- 8 ; provide 1" clearance to combustibles at b-vent at heater at all exterior locations.
- 9 ; complete roof penetration at south heater as discussed with contractor.
- 10 ; provide restroom sinks not to exceed 34"a.f.f. as per code.
- 11 ; urinal in men's restroom not to exceed 17" as per code.
- 12 ; insulate water supply line at sink in cooler.
- 13 ; complete ceiling tile's around hood in kitchen.
- 14 ; complete support of vents at back of ovens.
- 15 ; provide detail from architect at exterior landing exceed 2% at kitchen exit door. (106B)
- 16 ; provide health dept. final approval of septic prior to building final.
- 17 ; provide health dept. pre-walk inspection report prior to final.
- 18 ; complete set-up of seating and accessible signage as discussed with contractor.
- 19 ; provide positive connection of expansion tank of water heaters.



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

20 ; ; provide boiler final approval prior to building final inspection.

21 ; provide balance report with make-up air prior to final.

ok for kitchen training only

Sincerely,

Shannon King

Building Inspector 2

[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)

(253) 840-6684