

City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Sep 30, 2022 Inspection Result: FAILED

Permit Number: B-21-0480

Property Address: 401 15TH AVE SE, PUYALLUP, WA 98372;

Contractor: HOWARD S WRIGHT 415 1ST AVE N SEATTLE, WA 98109

To construct: RENOVATION OF EXSTNG GARAGE ~ MHS GOOD SAMLoading Dock

Area -

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1. complete tie wire at perimeter
 - 2. provide spreader bars or berc clips
 - 3.provide positive connection of wires at side walls to studs
 - 4. ceiling to be riveted on 2 sides and float on 2 sides
 - 5. complete mono coat on beams
 - 6.complete electrical

7.insulate water pips

Sincerely,

Shannon King

Building Inspector 2



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

ShannonK@PuyallupWA.gov (253) 840-6684