



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Oct 03, 2022                      **Inspection Result:**      **FAILED**

**Permit Number:** PRCTI20220811

**Property Address:** 3500 S MERIDIAN, Unit: 985, PUYALLUP, WA 98373;

**Contractor:** PINE RIDGE CONST MGMT LLC 1000 COMMERCE PARK DR ST 518  
WILLIAMSPORT, PA 17701 (570) 505-3890 Cameron Malchow 1000  
Commerce Park Drive Williamsport, PA 17701

**To construct:** Macy's SCOPE OF WORK CONSISTS OF INTERIOR ALTERATIONS LIMITED  
TO DEMOLITION OF NON-STRUCTURAL ELEMENTS, CONSTRUCTION OF  
NON-LOADBEARING PARTITIONS, MODIFICATIONS TO AFFECTED  
CEILINGS, AND INSTALLATION OF SHELVING LESS THAN 5'9" AND  
MILLWORK. NO CHANGE OF USE IS PROPOSED. NO CHANGES TO  
BUILDING ENVELOPE. BLDG ONLY - 8/24/2022 - MISCELLANEOUS  
REVISIONS TO PARTITIONS, CEILINGS AND FINISHES

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1. complete all perimeter tie wires as discussed with contractor
2. complete positive connection of diffusers as discussed with contractor
- 2 1. complete all ceiling grid requirements as discussed with contractor
2. provide splice connection detail sheet at main bar at the time of next inspection

Sincerely,



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

A handwritten signature in black ink that reads "Shannon King". The signature is written in a cursive style with a large, prominent 'S' and 'K'.

Shannon King

Building Inspector 2

[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)

(253) 840-6684