

City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Oct 05, 2022 Inspection Result: NOT READY

Permit Number: PRCTI20220811

Property Address: 3500 S MERIDIAN, Unit: 985, PUYALLUP, WA 98373;

Contractor: PINE RIDGE CONST MGMT LLC 1000 COMMERCE PARK DR ST 518

WILLIAMSPORT, PA 17701 (570) 505-3890Cameron Malchow 1000

Commerce Park Drive Williamsport, PA 17701

To construct: Macy's SCOPE OF WORK CONSISTS OF INTERIOR ALTERATIONS LIMITED

TO DEMOLITION OF NON-STRUCTURAL ELEMENTS, CONSTRUCTION OF

NON-LOADBEARING PARTITIONS, MODIFICATIONS TO AFFECTED CEILINGS, AND INSTALLATION OF SHELVING LESS THAN 5'9" AND MILLWORK. NO CHANGE OF USE IS PROPOSED. NO CHANGES TO BUILDING ENVELOPE. BLDG ONLY - 8/24/2022 - MISCELLANEOUS

REVISIONS TO PARTITIONS, CEILINGS AND FINISHES

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1. cancelled on site by contractor

Corrections:

- 1 1.remove flooring from under wall plates so it will bear on concrete
 - 2.complete framing on door opening
 - 3.complete all framing above mechanical equipment
 - 4.complete all fasteners at studs to wall plates 5.verify that electrical J/Box in concrete are abandoned where new wall plates are placed
 - 6. Provide architectural plans for all walls removed and demo
 - 7. Remove all abandoned ducting, framing, electrical conduit thru out space
- 2 1: inspection of of framing at exterior wall at s. e. corner only. (complete vapor barrier at exterior wall prior to inspection) not ready
- 3 1. provide attachment detail for this area from the architect
 - 2. provide electrical cover approval prior to next inspection

OF PUVALLES OF WASHINGS

City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

3.not ready

Sincerely,

Shannon King

Building Inspector 2 ShannonK@PuyallupWA.gov

(253) 840-6684