



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Oct 12, 2022

Inspection Result: **FAILED**

Permit Number: B-21-0480

Property Address: 401 15TH AVE SE, PUYALLUP, WA 98372;

Contractor: HOWARD S WRIGHT 415 1ST AVE N SEATTLE, WA 98109

To construct: RENOVATION OF EXSTNG GARAGE ~ MHS GOOD SAMLoading Dock
Area -

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1. complete tie wire at perimeter
2. provide spreader bars or berc clips
3. provide positive connection of wires at side walls to studs
4. ceiling to be riveted on 2 sides and float on 2 sides
5. complete mono coat on beams
6. complete electrical
7. insulate water pips
- 2 1. complete perimeter wire as discussed with contractor
2. complete positive attachment to light fixture
3. complete positive attachment of diffuser at main bar

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org