



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Oct 13, 2022 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCCP20220092

Property Address: 300 RIVER RD, PUYALLUP, WA 98371;

Contractor: WASHINGTON PATRIOT CONST LLC 10421 BURNHAM DR SUITE NW
GIG HARBOR, WA 98332

To construct: Construct underground utilities, storm drainage, replacements of
concrete curb, gutter, sidewalk, re-align driveway, replace driveways.
Remove & replace asphalt paving.

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: The existing side sewer line was inspected for reuse by the Cities collections department. They have given the approval to reuse the existing side sewer up to the 45 degree bend in 4th. The contractor must remove the 45 and lower the existing pipe to maintain 5' of cover at property line per city standard.

Corrections:

Sincerely,

Jeff Hill
Engineering Tech IV
Jhill@PuyallupWA.gov
(253) 841-5424