



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Oct 24, 2022 **Inspection Result:** **NOT READY**

Permit Number: PRDE20221364

Property Address: 1042 VALLEY AVE NW, PUYALLUP, WA 98371

Contractor: ASCENDENT LLC PO BOX 1150 SUMNER, WA 98390

To construct: Demolition of a wood framed house and shed including the foundation.
septic will be pumped, crushed and filled, asbestos will be removed.
(1042 VALLEY AVE NW)

On this day we have inspected your construction for **Utility Capping Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: -No one onsite.

Corrections:

- 1 1) Provide decommissioning cert. for septic system from TPCHD.
- 2 1) Decommission heating oil tank.
- 3 1) Provide decommissioning cert. for private water well.

Sincerely,

Michael Rosenau
Engineering Tech IV
MRosenau@PuyallupWA.gov
(253) 841-5411