



City of Puyallup  
**Engineering Division**  
333 S. Meridian, Puyallup, WA 98371  
(253) 864-4165  
[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

# Comment Notice

**Permit Application # PRFUP20221566**

October 24, 2022

The City has completed the review of the above-mentioned permit submittal. Below please find the permit submittal review comments from your review team. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

**Engineering Review** (Reviewed By: Yianni Charitou, (253)435-3612, YCharitou@PuyallupWA.gov)

- ♦ Site plan shall be dimensions, drawn to scale, include a scale bar, boundaries of the property, dimensions of property, square footage of property, parking areas, north arrow, location of existing and proposed facilities indicating setback distances from property lines. Work within WSDOT's jurisdiction requires a site plan stamped with WSDOT's approval. If you have not received WSDOT approval, please email your plans to [olympicregionutilities@wsdot.wa.gov](mailto:olympicregionutilities@wsdot.wa.gov) prior to applying with the City of Puyallup.

Work within WSDOT's jurisdiction requires a traffic control plan stamped with WSDOT's approval. If you have not received WSDOT approval, please email your plans to [olympicregionutilities@wsdot.wa.gov](mailto:olympicregionutilities@wsdot.wa.gov) prior to applying with the City of Puyallup.

- ♦ Modify cones arrangement to keep northbound 5TH ST SE open to traffic at the intersection of 35TH AVE SE [TCP-1, sheet 1 of 6]

To resubmit, you must address all comments and complete the [resubmittal form](#).

When you are ready to resubmit, you can do so using the customer portal, by **uploading a "new version" of the submittal requirement**. In addition, if any resubmittal fees have been assessed, **you will need to pay your resubmittal fee at the time of resubmittal. Your resubmittal will not be processed until the fee has been paid.** Please note, partial resubmittals will be deemed incomplete and returned.

The review team may have also added conditions to the permit application that are not listed above. The permit conditions can be found in the CityView portal. Please note, some of the conditions may need to be resolved prior to permit issuance.

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center

(253) 864-4165 option 1

[permitcenter@puyallupwa.gov](mailto:permitcenter@puyallupwa.gov)