



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Comment Notice

Permit Application # PRPL20221668

October 31, 2022

The City has completed the review of the above-mentioned permit submittal. Below please find the permit submittal review comments from your review team. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

Plumbing Review (Reviewed By: David Leahy, (253)435-3618, DLeahy@PuyallupWA.gov)

◆ Plans that were submitted: 1) Do not clearly define the location of the new floor drain or possible required trap primer or slope toward the drain, as well as where this new floor drain is being tied into for the rest of the plumbing system all required in the 2018 Uniform Plumbing Code. 2) The engineers stamp on these plans cannot be somewhat crossed out like it is as once it is stamped then it is only them that can change it. 3) will need to submit new plans with all items clearly addressed for review.

To resubmit, you must address all comments and complete the [resubmittal form](#).

When you are ready to resubmit, you can do so using the customer portal, by **uploading a “new version” of the submittal requirement**. In addition, if any resubmittal fees have been assessed, **you will need to pay your resubmittal fee at the time of resubmittal. Your resubmittal will not be processed until the fee has been paid.** Please note, partial resubmittals will be deemed incomplete and returned.

The review team may have also added conditions to the permit application that are not listed above. The permit conditions can be found in the CityView portal. Please note, some of the conditions may need to be resolved prior to permit issuance.

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center

(253) 864-4165 option 1

permitcenter@puyallupwa.gov