



CITY OF PUYALLUP
Development & Permitting Services
 333 S. Meridian, Puyallup, WA 98371
 (253) 864-4165
www.cityofpuyallup.org

Permit No:
 PRFA20221585

FIRE ALARMS

Puyallup, WA

Job Address	Address: 401 15TH AVE SE, PUYALLUP, WA 98372 Parcel # 9810000014	ISSUED November 01, 2022
Owner	MULTICARE HEALTH SYSTEM PO BOX 5299 MS 737-4-FSAD TACOMA, WA 98415	
Applicant	Janet Stebbins 9520 10th Avenue S., Suite 100 SEATTLE, WA 98108 (206) 291-1400 janet.stebbins@jci.com	
Contractor	JOHNSON CONTROLS FIRE PROTECTION 9520 10TH AVE SE, STE SEATTLE, WA 98108-5068 WA L&I #:	
Description of Work	Modify existing fire alarm system Good Samaritan Hospital, Level 1 East. Adding (5) relays, (1) notification device. Joint venture between Johnson Controls Fire Protection and Precision Electric Group.	
Permit Types	Fire Alarms	
Expiration Date:	April 30, 2023	

Building Components:

Quantity	Units	Description	Unit Cost	Subtotal Cost
6	DEVICES	Fire Alarm and Detection System and Related Equipment, Alteration	\$0.00	\$0.00
Total Value of Work:				\$0.00

Standard Conditions:

1. • Appointment required for all inspections am/pm is not guaranteed without appointment. Larger systems taking more than 1 hour will require 48-72hr notice prior to scheduling.
 - Provide plans and permit on site for inspection.
 - Complete labor and industries inspections prior to requesting city inspection.
 - Device maps required at the annunciator and fire alarm panel prior to calling in final. The annunciator map will need to be weatherproof.
 - Fire alarm system shall be placarded per NFPA 72. The UL certificate shall be posted at time of final inspection. The system will need to be UL certified.
 - Pre-test shall be conducted with a printout for inspector at time of inspection.
 - Labeling of all devices above and below ceiling required.
 - Due to unforeseeable construction design, all device locations to be field verified for compliance.
- Schedule your inspection online through the city of puyallup online permit system after requesting appointment from inspector. Fire Inspections are Monday – Thursday there will be no inspections on Fridays.
 David Drake 253-864-4171 ddrake@puyallupwa.gov

Permit is valid 180 days from date of issuance. Permit validity is subject to all adhering to all applicable codes, ordinances and standards, and conditions of this permit.

I certify that I am the owner of this property or the owner's authorized agent, including an appropriately licensed contractor. I have read and examined this application and furnished true and correct information. I will comply with all provisions of law and ordinances governing this type of construction work, whether specific herein or not. By submitting this application, I give the jurisdiction permission to enter the property to perform inspections. The granting of this permit does not presume or give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. I understand that failure to comply with the above may result in revocation of the permit.

Applicant:
Janet Stebbins