




**DDrake** 



THE APPROVED CONSTRUCTION PLANS AND ALL ENGINEERING MUST BE POSTED ON THE JOB AT ALL INSPECTIONS IN A VISIBLE AND READILY ACCESSIBLE LOCATION.


Approval of submitted plans is not an approval of omissions or oversight by this office or noncompliance with any applicable regulations of local government. The contractor is responsible for making sure that the building complies with all applicable building codes and regulations of the local government.





FIRE ALARM RISER DIAGRAM

SCHEMATIC: NO SCALE



## FIRE ALARM DEVICE MOUNTING HEIGHTS

SCALE: NOT TO SCALE

## NOTES:

- I. LOCATE CEILING MOUNTED HEAT/SMOKE DETECTORS ON THE BOTTOM OF THE DECK/SUSPENDED CEILING (NOT ON BOTTOM OF STRUCTURAL MEMBERS), AND AS INDICATED IN NFPA 72.
- 2. LOCATE CEILING MOUNTED NOTIFICATION DEVICES ON BOTTOM OF BEAMS OR JOISTS; WITH CLEAR LINE OF SITE IN ALL DIRECTIONS; NO GREATER THAN THIRTY (30) FEET ABOVE THE FINISHED FLOOR; AND AS INDICATED IN NFPA 72.
- 3. LOCATE CEILING MOUNTED NOTIFICATION DEVICES FLUSH WITH THE SUSPENDED CEILING; ALIGNED WITH LIGHTING, SPRINKLERS, AND OTHER ARCHITECTURAL FIXTURES; WITH CLEAR LINE OF SITE IN ALL
- DIRECTIONS; NO GREATER THAN THIRTY (30) FEET A.F.F.; AND AS INDICATED IN NFPA 72. 4. LOCATE WALL MOUNTED NOTIFICATION DEVICES AT 80" A.F.F TO BOTTOM OF BACK BOX.

6. MEASURED TO THE OPERABLE PART OF THE PULL STATION.

- 5. COORDINATE EXACT MOUNTING HEIGHT OF CONTROL PANELS, ANNUNCIATORS, AND POWER SUPPLIES
- WITH THE GENERAL CONTRACTOR, ELECTRICAL CONTRACTOR AND AHJ PRIOR TO INSTALLATION.

**STANLEY**. Security

#101 -5926

Supper Supplements # 4307 S Meridian
Puyallup, WA 98373-59

**Sheet Number** 

**RISER** 

1 of 1