



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

# Comment Notice

**Permit Application # PRCTI20221484**

November 4, 2022

The City has completed the review of the above-mentioned permit submittal. Below please find the permit submittal review comments from your review team. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

**Building Review** (Reviewed By: David Leahy, (253)435-3618, [DLeahy@PuyallupWA.gov](mailto:DLeahy@PuyallupWA.gov))

- ◆ Need to provide more details on all attachments to ceiling and bracing for seismic restraint. Page A101.2 details 5 and 6 of plans.
- ◆ Are these new full height walls or just soffits? Not real clear to me at this point. Page A101.2, detail 2 first floor plan.
- ◆ Would need to specify the MFR for the clips and the installation of that product on the plans. Page A502.2, detail C3.
- ◆ This is not referenced in the 2018 IBC nor do these seismic zones applicable in the current codes. Page A502.2, note A in general notes.
- ◆ Provide complete sets of plans a submittal form along with a response letter showing how all comments were addressed.

The markup plans are available in the Portal with comment letter.

To resubmit, you must address all comments and complete the [resubmittal form](#).

When you are ready to resubmit, you can do so using the customer portal, by **uploading a "new version" of the submittal requirement**. In addition, if any resubmittal fees have been assessed, **you will need to pay your resubmittal fee at the time of resubmittal**. **Your resubmittal will not be processed until the fee has been paid**. Please note, partial resubmittals will be deemed incomplete and returned.

The review team may have also added conditions to the permit application that are not listed above. The permit conditions can be found in the CityView portal. Please note, some of the conditions may need to be resolved prior to permit issuance.

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center

(253) 864-4165 option 1

[permitcenter@puyallupwa.gov](mailto:permitcenter@puyallupwa.gov)