



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Nov 14, 2022                      **Inspection Result:**     **PARTIAL PASS**

**Permit Number:** PRCTI20220873

**Property Address:** 2504 E MAIN, PUYALLUP, WA 98372;

**Contractor:** POE CONSTRUCTION INC PO BOX 899 AUBURN, WA 98071-0899

**To construct:** Expansion of existing conditioned office and mezzanine TI in existing warehouse building, including new elevator. New break room, restrooms and offices in warehouse area. Incorporation of light manufacturing equipment and processes within warehouse. Envelope upgrades for full conditioning of warehouse space per deferred HVAC Design/Build submittal. Repurposing of existing on-site trailer parking area with auto parking stalls to support new manufacturing use. REVISION (1) - 10/28/2022 REMOVAL OF ONE PRIVATE OFFICE AND ENLARGEMENT OF ANOTHER OFFICE

On this day we have inspected your construction for **Wallboard / Drywall Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** 1.exterior drywall of offices approved

**Corrections:**

Sincerely,

Shannon King



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Building Inspector 2

[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)

(253) 840-6684