



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Comment Notice

Permit Application # PRCTI20221709

November 22, 2022

The City has completed the review of the above-mentioned permit submittal. Below please find the permit submittal review comments from your review team. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

Building Review (Reviewed By: Janelle Montgomery, (253)770-3328, JMontgomery@PuyallupWA.gov)

◆ S-503 and S-501

PROVIDE STRUCTURAL ENGINEER SEAL ON FOUNDATION MODIFICATIONS.

◆ NOT LEDIGIBLE

PROVIDE CLEAR COMPLIANCE FORM IF REQUIRED - AS-BUILT FOR OFFICE PERMIT FOR REFERENCE ONLY

◆ SSK-A: Provide engineer seal on all plan sheets with structural work being installed.

◆ Provide a floor plan that shows location of proposed equipment, include aisle width and travel distance to exits

Typically calculations are submitted with Engineer seal and structural plans sheets showing installation of items are provided in the plan set for installation and inspection. Provide separate engineer structural sealed plans.

◆ S3: ENGINER SEALED REQUIRED.

◆ NO COMMENTS AVAILABLE

◆ SEE COMMENTS ON STRUTURAL CALCULATIONS PACKET FOR BRIDGE CRANE. APPLY TO THIS STRUCTURAL CALCULATIONS PACKET FOR EQUIPMENT FOUNDATION
NEED ALL SHEETS SEALED BY ENGINEER

To resubmit, you must address all comments and complete the [resubmittal form](#).

When you are ready to resubmit, you can do so using the customer portal, by **uploading a "new version" of the submittal requirement**. In addition, if any resubmittal fees have been assessed, **you will need to pay your resubmittal fee at the time of resubmittal**. **Your resubmittal will not be processed until the fee has been paid**. Please note, partial resubmittals will be deemed incomplete and returned.

The review team may have also added conditions to the permit application that are not listed above. The permit conditions can be found in the CityView portal. Please note, some of the conditions may need to be resolved prior to permit issuance.

If you need assistance with resubmitting your corrections, please contact the Permit Center.



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Sincerely,

City of Puyallup Permit Center

(253) 864-4165 option 1

permitcenter@puyallupwa.gov