



City of Puyallup  
**Building Division**  
333 S. Meridian, Puyallup, WA 98371  
(253) 864-4165  
www.cityofpuyallup.org

# Comment Notice

**Permit Application # PRCTI20220873**

November 23, 2022

The City has completed the review of the above-mentioned permit submittal. Below please find the permit submittal review comments from your review team. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

**Engineering Review** (Reviewed By: Jamie Carter, (253)435-3616, JCarter@puyallupwa.gov)

- ♦ The City of Puyallup is currently operating under the 2018 version of the IBC with Washington State Amendments. Revise the submittal with the proper references and, if warranted by the newer reference, adjust the calculations to match.
- ♦ Most of the reference bubbles on the submitted Sheet A0.1 refer to Sheet A0.2. Include Sheet A0.2 if required for the scope of this revision, or remove the references from this submittal.

To resubmit, you must address all comments and complete the [resubmittal form](#).

When you are ready to resubmit, you can do so using the customer portal, by **uploading a “new version” of the submittal requirement**. In addition, if any resubmittal fees have been assessed, **you will need to pay your resubmittal fee at the time of resubmittal. Your resubmittal will not be processed until the fee has been paid.** Please note, partial resubmittals will be deemed incomplete and returned.

The review team may have also added conditions to the permit application that are not listed above. The permit conditions can be found in the CityView portal. Please note, some of the conditions may need to be resolved prior to permit issuance.

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center

(253) 864-4165 option 1

[permitcenter@puyallupwa.gov](mailto:permitcenter@puyallupwa.gov)