

City of Puyallup **Engineering Division** 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection:	Dec 05, 2022	Inspection Result:	FAILED
Permit Number: Property Address:	E-20-0612 3213 WILDWOOD PARK	DR, PUYALLUP, WA 983	74;
Contractor:	PEASE & SONS PO BOX	44100 TACOMA, WA 9	8444 Brandon Haskins
To construct:	10601 Waller Rd E Tacc CIVII S ~ FERRUCCLIHS I		
To construct.	UPDATED**		

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: review after site meeting. corrections list.

Corrections:

- 1 finish testing and tv'ing storm lines. fix all bellies and failed storm lines. retest and camera. Once passed finish grout all CB's and MH's and install ladders
- 2 raise all castings from paving
- 3 fix grade bust on the curb at the exit of the parent drop off and Wildwood DR.
- 4 all the wheelchair ramps are out of ada compliance. Remove ramps and install per current ADA standards.
- 5 rotate hydrant in the bus loop. install all Storz fittings on all hydrants.
- 6 update TESC's (socks in CB's and silt fence around working areas)
- 7 grind and overlay damaged areas in Wildwood Park Drive from equipment.
- 8 once final paved remove temp striping and repaint
- 9 replace all cracked and broken curb and sidewalk

Sincerely,

Jeff Hill Engineering Tech IV



City of Puyallup **Engineering Division** 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

Jhill@PuyallupWA.gov (253) 841-5424