



# Comment Notice

**Permit Application # PRFUP20221830**

December 6, 2022

The City has completed the review of the above-mentioned permit submittal. Below please find the permit submittal review comments from your review team. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

**Engineering Review** (Reviewed By: Linda Lian, (253)841-5577, LindaL@PuyallupWA.gov)

- ◆ Please provide a TCP drawn with the correct lane configuration. Signs overlaid on an image of a street is not an acceptable TCP. [TCP Turnkey Shaw Rd TCP 1 09\_14\_22 rev1(1)\* Sheet 1 of 9]
- ◆ Aerial crossing is limited to 3-minutes, otherwise the work will be done at night. State if it will require to be done at night. [Site Plan Puyallup Fredrickson Gen Plant Sheet 2/5]
- ◆ Aerial crossing is limited to 3-minutes, otherwise the work will be done at night. State if it will require to be done at night. [Site Plan Puyallup Fredrickson Gen Plant Sheet 3/5]
- ◆ Aerial crossing is limited to 3-minutes, otherwise the work will be done at night. State if it will require to be done at night. [Site Plan Puyallup Fredrickson Gen Plant Sheet 3/5]
- ◆ Uniformed Police Officer required at this intersection. [TCP Turnkey Shaw Rd TCP 1 09\_14\_22 rev1(1)\* Sheet 1 of 9]
- ◆ Please provide a TCP drawn with the correct lane configuration. Signs overlaid on an image of a street is not an acceptable TCP. [TCP Turnkey Shaw Rd TCP 1 09\_14\_22 rev1(1)\* Sheet 2 of 9]
- ◆ Please provide a TCP drawn with the correct lane configuration. Signs overlaid on an image of a street is not an acceptable TCP. [TCP Turnkey Shaw Rd TCP 1 09\_14\_22 rev1(1)\* Sheet 4 of 9]
- ◆ Please provide a TCP drawn with the correct lane configuration. Signs overlaid on an image of a street is not an acceptable TCP. [TCP Turnkey Shaw Rd TCP 1 09\_14\_22 rev1(1)\* Sheet 6 of 9]
- ◆ Please provide a TCP drawn with the correct lane configuration. Signs overlaid on an image of a street is not an acceptable TCP. [TCP Turnkey Shaw Rd TCP 1 09\_14\_22 rev1(1)\* Sheet 7 of 9]
- ◆ Please provide a TCP drawn with the correct lane configuration. Signs overlaid on an image of a street is not an acceptable TCP. [TCP Turnkey Shaw Rd TCP 1 09\_14\_22 rev1(1)\* Sheet 8 of 9]
- ◆ Please provide a TCP drawn with the correct lane configuration. Signs overlaid on an image of a street is not an acceptable TCP. [TCP Turnkey Shaw Rd TCP 1 09\_14\_22 rev1(1)\* Sheet 9 of 9]
- ◆ This portion of work will be done at night. [Site Plan Puyallup Fredrickson Gen Plant Sheet 2/5]
- ◆ A uniformed police officer is required at this intersection. [Site Plan Puyallup Fredrickson Gen Plant Sheet 2/5]

To resubmit, you must address all comments and complete the [resubmittal form](#).

When you are ready to resubmit, you can do so using the customer portal, by **uploading a "new version" of the submittal requirement**. In addition, if any resubmittal fees have been assessed, **you will need to pay your resubmittal fee at the time of resubmittal**. **Your resubmittal will not be processed until the fee has been paid**. Please note, partial resubmittals will be deemed incomplete and returned.



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

---

The review team may have also added conditions to the permit application that are not listed above. The permit conditions can be found in the CityView portal. Please note, some of the conditions may need to be resolved prior to permit issuance.

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center

(253) 864-4165 option 1

[permitcenter@puyallupwa.gov](mailto:permitcenter@puyallupwa.gov)