



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Dec 08, 2022

Inspection Result: **FAILED**

Permit Number: PRCTI20221400

Property Address: 4227 S MERIDIAN, Unit: C, PUYALLUP, WA 98373;

Contractor: CENSOR COMMERCIAL CONSTRUCTION LLC 2525 NE TWIN KNOLLS, S
TE BEND, OR 97701

To construct: H & R BLOCK: Interior TI: includes demo of interior partitions/doors,
relocation of select ceiling fixtures; To include new interior
partitions/doors, and outlets: Adding a second restroom. (1 Men's and
1 Women's both accessible)

On this day we have inspected your construction for **Combination Frame And Rough In Inspection**
and we find the following result of the inspection. If there are any questions, please contact the
inspector below.

Comments:

Corrections:

- 1 1 ; remove screws from top track to ceiling grid as discussed with contractor.
- 2 ; seal penetration in top plates at wood construction at plumbing penetrations.

Sincerely,

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

(253) 840-6684