



City of Puyallup
Engineering Division
333 S. Meridian, Puyallup, WA 98371
(253) 864-4165
www.cityofpuyallup.org

Comment Notice

Permit Application # PRCCP20221323

December 8, 2022

The City has completed the review of the above-mentioned permit submittal. Below please find the permit submittal review comments from your review team. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

Engineering Civil Review (Reviewed By: Jamie Carter, (253)435-3616, JCarter@puyallupwa.gov)

- ♦ SWPPP is incomplete. Acknowledging that this is reconstruction and a simpler project than most, we do not require the entire ECY checklist to be satisfied (Checklist: Vol II, Section 2.4 of the 2019 SWMMWW), but the SWPPP is a standalone document and as such the following shall be included:
 - o City of Puyallup project number - PRCCP20221323
 - o Brief project description that includes narrative and drawings - Include ESC sheet - acknowledging that the ESC sheet is submitted under the Erosion and Sediment Control Plan submittal box, the ESC sheet shall also be included in the SWPPP. 8 ½ x 11 OK.
 - o Include CESCL contact and phone number in SWPPP. If no CESCL has been designated for the project yet, provide a place to include the information once the CESCL has been designated.
 - o If no construction entrance is possible, address track out in the narrative: i.e. daily sweeping, wheel washing, etc., as necessary.
- ♦ CIVIL PLANS - Sheet C1 - there are 4 inlets within the curb along the frontage of the apartments that have the possibility to receive water from the project. These inlets should also be provided with catch basin inserts. Should a large rain event or some type of spill or overflow occur these CBs would be the receiving point for anything that flows out into the ROW along the gutter. The sheet does not need to be expanded, a note to protect the ROW catch basins along the project frontage will suffice.

To resubmit, you must address all comments and complete the [resubmittal form](#).

When you are ready to resubmit, you can do so using the customer portal, by **uploading a "new version" of the submittal requirement**. In addition, if any resubmittal fees have been assessed, **you will need to pay your resubmittal fee at the time of resubmittal**. **Your resubmittal will not be processed until the fee has been paid**. Please note, partial resubmittals will be deemed incomplete and returned.

The review team may have also added conditions to the permit application that are not listed above. The permit conditions can be found in the CityView portal. Please note, some of the conditions may need to be resolved prior to permit issuance.

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

City of Puyallup Permit Center

(253) 864-4165 option 1

permitcenter@puyallupwa.gov