



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Dec 20, 2022

Inspection Result: NOT READY

Permit Number: PRCTI20221400

Property Address: 4227 S MERIDIAN, Unit: C, PUYALLUP, WA 98373;

Contractor: CENSOR COMMERCIAL CONSTRUCTION LLC 2525 NE TWIN KNOLLS, S
TE BEND, OR 97701

To construct: H & R BLOCK: Interior TI: includes demo of interior partitions/doors,
relocation of select ceiling fixtures; To include new interior
partitions/doors, and outlets: Adding a second restroom. (1 Men's and
1 Women's both accessible)

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1 ; talked about ceiling grid requirements.

Corrections:

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684