



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 09, 2023

Inspection Result: **FAILED**

Permit Number: E-21-0221

Property Address: 812 N MERIDIAN, PUYALLUP, WA 98371;

Contractor: PSE - POTELCO 5807 MILWAUKEE AVE E PUYALLUP, WA 98372

To construct: JOB #101130457 Permit extended until 02/01/2022 LL Permit extended to 7/23/2022 for pole removal and restoration CT Permit extended to 12/18/22 for restoration CT Final extension provided to 3/17/23 to complete restoration CT

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: The sidewalk finish was compromised due to rain activity. Although the panels were covered, they were not immediately covered. There is no indication of a broomed finish and the western groover is missing. The sidewalk panels will need to be repoured prior to permit closure.

Corrections:

- 1 Sidewalk panels must be repoured due to excessive rain that compromised the finish.

Sincerely,

Cheryl Trimble

Engineer Tech II

CTrimble@PuyallupWA.gov

(253) 841-5464