



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jan 10, 2023                      **Inspection Result:**     **FAILED**

**Permit Number:** PRCCP20220770

**Property Address:** 1601 39TH AVE SE, PUYALLUP, WA 98374;

**Contractor:** ABSHER CONSTRUCTION CO PO BOX 280 PUYALLUP, WA 98371-0152  
Raygan Kettman 1001 SHAW RD E PUYALLUP, WA 98372

**To construct:** The project proposes a new STEM classroom and laboratory building and a new parking lot, net gain of 100 stalls. Improvements include asphalt paving, concrete paving, a new building, utilities services for the new building, and stormwater management. Utility services include domestic water and water main, sewer main and services, natural gas, primary and secondary power, and telecommunications. Modifications to the existing parking lot east of the building and sidewalks adjacent to the building will occur. A belowground detention facility utilizing Stormtech MC-7200 chambers are proposed for stormwater flow control. A bioretention facility will be used upstream of the proposed flow control facility to provide stormwater quality treatment for pollution generating impervious surfaces (PGIS).

On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** There is track out around the loop, up to where the trucks are entering the stop sign and fenced in area. This needs to be kept swept also. If sweeping it to the gutter pan it needs to be picked up. Trucks are not checking there load after being loaded. Dirt on the rear end and on the drop axle.

**Corrections:**

- 1 - Repair and maintain construction entrance.
- Zero track out. This needs to be cleaned up at time of track out.



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Sincerely,

Jason Little  
Engineering Tech IV  
JLittle@PuyallupWA.gov  
(253) 435-3636