



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 10, 2023

Inspection Result: PARTIAL PASS

Permit Number: PRCTI20220873

Property Address: 2504 E MAIN, PUYALLUP, WA 98372;

Contractor: POE CONSTRUCTION INC PO BOX 899 AUBURN, WA 98071-0899

To construct: Expansion of existing conditioned office and mezzanine TI in existing warehouse building, including new elevator. New break room, restrooms and offices in warehouse area. Incorporation of light manufacturing equipment and processes within warehouse. Envelope upgrades for full conditioning of warehouse space per deferred HVAC Design/Build submittal. Repurposing of existing on-site trailer parking area with auto parking stalls to support new manufacturing use. REVISION (1) - 10/28/2022 REMOVAL OF ONE PRIVATE OFFICE AND ENLARGEMENT OF ANOTHER OFFICE REVISION (2) 11/18/2022 - RECALCULATION AND RELOCATION OF EV CHARGING INFRASTRUCTURE

On this day we have inspected your construction for **Exhaust/Vent Fans Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1 ; approved rough-in of ware house break room and 1st floor office only

Corrections:

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684