



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 11, 2023

Inspection Result: **FAILED**

Permit Number: PRDE20221756

Property Address: 1106 VALLEY AVE NW, PUYALLUP, WA 98371;

Contractor: ASCENDENT LLC PO BOX 1150 SUMNER, WA 98390

To construct: Demolition of a SFR, two out buildings, decom of septic and capping of water from well (well to remain for 1036 use) asbestos removal, erosion control

On this day we have inspected your construction for **Utility Capping Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: The applicant shall demolish the existing private well per Tacoma Pierce County Health Department standards or install an approved reduced pressure backflow device on the City water service. A well decommissioning certificate shall be filed with Pierce County and a copy submitted to the City of Puyallup. The septic tank needs to be demoed as well.

Corrections:

- 1 The applicant shall demolish the existing private well per Tacoma Pierce County Health Department standards or install an approved reduced pressure backflow device on the City water service. A well decommissioning certificate shall be filed with Pierce County and a copy submitted to the City of Puyallup.
- 2 demo the septic tank

Sincerely,

Jeff Hill
Engineering Tech IV
Jhill@PuyallupWA.gov
(253) 841-5424



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org