



CITY OF PUYALLUP
Development & Permitting Services
 333 S. Meridian, Puyallup, WA 98371
 (253) 864-4165
www.cityofpuyallup.org

Permit No:
 PRFA20221928

FIRE ALARMS

Puyallup, WA

Job Address	Address: 3500 S MERIDIAN, Unit: 115, PUYALLUP, WA 98373 Parcel # 6021010051	ISSUED January 19, 2023
Owner	CAFARO NORTHWEST PARTNERSHIP PO BOX 586 ANNANDALE, NJ 08801	
Applicant	Lindsey Leslie 801 Valley Avenue , Suite D PUYALLUP, WA 98372 (253) 840-9900 LindseyL@redhawkfp.com	
Contractor	RED HAWK FIRE PROTECTION LLC 801 VALLEY AVE NW PUYALLUP, WA 98371-3230 WA L&I #:	
Description of Work	INSTALLATION OF REMOTE TEST STATIONS ON ALL EXISTING DUCT DETECTORS. INSTALL NEW PULL STATION FOR NEW EGRESS DOOR. INSTALL NEW SMOKE DETECTORS TO ACCOMODATE FOR NEW DEMISING WALL. RELOCATE EXISTING DEVICES FOR OLD RESTROOM AREA THAT IS BEING DEMOLISHED. NEW LEVEL 360 UNIT 900-20	
Permit Types	Fire Alarms	
Expiration Date:	July 18, 2023	

Building Components:

Quantity	Units	Description	Unit Cost	Subtotal Cost
14	DEVICES	Fire Alarm and Detection System and Related Equipment, Alteration	\$0.00	\$0.00
Total Value of Work:				\$0.00

Standard Conditions:

1. • Appointment required for all inspections am/pm is not guaranteed without appointment. Larger systems taking more than 1 hour will require 48-72hr notice prior to scheduling.
 - Provide plans and permit on site for inspection.
 - Complete labor and industries inspections prior to requesting city inspection.
 - Above ceiling detection is required.
 - Device maps required at the annunciator and fire alarm panel prior to calling in final. The annunciator map will need to be weatherproof.
 - Total coverage is required, subject to field inspection. Comply with NFPA 72.
 - Fire alarm system shall be placarded per NFPA 72. The UL certificate shall be posted at time of final inspection. The system will need to be UL certified.
 - Pre-test shall be conducted with a printout for inspector at time of inspection.
 - Labeling of all devices above and below ceiling required.
 - RTU'S and smoke dampeners will be required to be tested during inspection.

- The city of Puyallup allows one FACP per building. The panel will need to be large enough to handle multiple tenants if applicable.
- In existing buildings all above ceiling detection is to remain. Do not remove.
- Due to unforeseeable construction design, all device locations to be field verified for compliance.

Schedule your inspection online through the city of puyallup online permit system after requesting appointment from inspector. Fire Inspections are Monday – Thursday there will be no inspections on Fridays.

David Drake 253-864-4171 ddrake@puyallupwa.gov

Permit is valid 180 days from date of issuance. Permit validity is subject to all adhering to all applicable codes, ordinances and standards, and conditions of this permit.

I certify that I am the owner of this property or the owner's authorized agent, including an appropriately licensed contractor. I have read and examined this application and furnished true and correct information. I will comply with all provisions of law and ordinances governing this type of construction work, whether specific herein or not. By submitting this application, I give the jurisdiction permission to enter the property to perform inspections. The granting of this permit does not presume or give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. I understand that failure to comply with the above may result in revocation of the permit.

Applicant:
Lindsey Leslie