



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 25, 2023

Inspection Result: **FAILED**

Permit Number: PRCTI20221628

Property Address: 3511 5TH ST SE, PUYALLUP, WA 98374;

Contractor: REEVE-KNIGHT CONSTRUCTION INC 128 ASCOT DR ROSEVILLE, CA
95661 Noland Rutledge 16715 48th St. E. Lake Tapps, WA 98391, WA
98391

To construct: Interior remodel of the existing Unisex, Men's, and Women's Restroom

On this day we have inspected your construction for **Comment Building Div Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 ; provide manufacturers warranty at time of final inspection.
- 2 ; reconnect all electrical boxes to wall or a approved location with sealed electrical conduit.
- 3 ; complete all condensate drain as discussed with contractor.
- 4 ; repair damaged termination cap at south side of roof.
- 5 ; complete all downspout as discussed with contractor.

Sincerely,

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org