



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jan 26, 2023

**Inspection Result:** PARTIAL PASS

**Permit Number:** PRFUP20221853

**Property Address:** 1620 RIVER RD, PUYALLUP, WA 98371;

**Contractor:** PSE - INFRASOURCE 3130 S 38TH ST TACOMA, WA 98409

**To construct:** 109145905 - Install short side gas service @ 40' S CL RIVER ROAD & 640' W CL 15TH ST with 3x5 cut in hard surface right of way

On this day we have inspected your construction for **Job Start Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** TMI set up traffic control with an eastbound lane shift. Infrasource pulled the steel plate from the sidewalk and tied in at the main. The crew installed a valve in soft surface at the back of walk and a locate cover / valve in the sidewalk over the main. This was required due in part to the depth of the main. They bedded the main in sand and backfilled with 5/8" minus, setting the locate cover in cold mix and compacting it. They cleaned and swept the gutter and sidewalk and reopened the lane prior to 2pm.

**Corrections:**

- 1 Permit closure pending restoration.

There were 5 pits in the parking lot that will require asphalt patching as well as the sidewalk panel replacement. Permit will be closed once all restoration has been completed.

Sincerely,

Cheryl Trimble

Engineer Tech II

CTrimble@PuyallupWA.gov



City of Puyallup

---

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

(253) 841-5464