



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 31, 2023

Inspection Result: NOT READY

Permit Number: B-20-0993

Property Address: 3213 WILDWOOD PARK DR, PUYALLUP, WA 98374;

Contractor: PEASE & SONS PO BOX 44100 TACOMA, WA 98444

To construct: 10-CLASSRM ADDITION TO THE EXISTING JHS ~ FERRUCCI JHS *E-
20-0612 CIVIL *

On this day we have inspected your construction for **Comment Building Div Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; approved as t.c.o. in rooms- 207 except sink and doors,208 except sink, range exhaust, and hammer arrestor for refrigerator,101k,101j complete office door with door hardware,101i complete office door with door hardware,101h complete office door with door hardware,101g complete office door with door hardware, 101g complete office door with door hardware, 101b ,complete office door with door hardware, 101a,105d complete office door with door hardware, 105a complete install of sink, approved for 30 days from 3/10/2022
- 2 1 ; inspection of energy at south and east walls of commons addition only.
- 3 1. Provide install instructions for fire dampers at time of next inspection
- 4 i. Furniture stocking. Only stock in rooms with approved and completed ceilings. Conditional on providing access for any trade or inspection; including above ceiling fire alarm.
ii. Contractor and owner shall provide and direct onsite safety.
iii. Inspection walkthrough will be requested from Monday for Fire Prevention.
iv. Inspection review by the building inspector and engineering inspectors is required for furniture stocking.
- 5 1 ; provide fire final approval prior to building final inspection for T.C.O. of entry B.

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684