



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jan 12, 2023

Inspection Result: **PARTIAL PASS**

Permit Number: E-20-0612

Property Address: 3213 WILDWOOD PARK DR, PUYALLUP, WA 98374;

Contractor: PEASE & SONS PO BOX 44100 TACOMA, WA 98444 Brandon Haskins
10601 Waller Rd E Tacoma, WA 98446 (253) 370-6559

To construct: CIVILS ~ FERRUCCI JHS REMODEL & ADDITION**2021 STORM SDC FEES
UPDATED**

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Titan is grouting manholes.

I spoke with Peas about the corrections from past inspections. not much has changed.

Corrections:

- 1 finish testing and tv'ing storm lines. fix all bellies and failed storm lines. retest and camera.
Once passed finish grout all CB's and MH's and install ladders
- 2 raise all castings from paving
- 3 fix grade bust on the curb at the exit of the parent drop off and Wildwood DR.
- 4 all the wheelchair ramps are out of ada compliance. Remove ramps and install per current ADA standards.
- 5 rotate hydrant in the bus loop. install all Storz fittings on all hydrants.
- 6 grind and overlay damaged areas in Wildwood Park Drive from equipment.
- 7 once final paved remove temp striping and repaint
- 8 replace all cracked and broken curb and sidewalk
- 9 delineate around work and staging areas. At all times keep a well-marked path for students and staff.

Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Jeff Hill

Engineering Tech IV

Jhill@PuyallupWA.gov

(253) 841-5424