



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Feb 03, 2023

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** E-20-0612

**Property Address:** 3213 WILDWOOD PARK DR, PUYALLUP, WA 98374;

**Contractor:** PEASE & SONS PO BOX 44100 TACOMA, WA 98444 Brandon Haskins  
10601 Waller Rd E Tacoma, WA 98446 (253) 370-6559

**To construct:** CIVILS ~ FERRUCCI JHS REMODEL & ADDITION\*\*2021 STORM SDC FEES  
UPDATED\*\*

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** landscapers are working on the ball field

**Corrections:**

- 1 finish testing and tv'ing storm lines. fix all bellies and failed storm lines. retest and camera. Once passed finish grout all CB's and MH's and install ladders
- 2 raise all castings from paving
- 3 fix grade bust on the curb at the exit of the parent drop off and Wildwood DR.
- 4 all the wheelchair ramps are out of ada compliance. Remove ramps and install per current ADA standards.
- 5 rotate hydrant in the bus loop. install all Storz fittings on all hydrants.
- 6 grind and overlay damaged areas in Wildwood Park Drive from equipment.
- 7 once final paved remove temp striping and repaint
- 8 replace all cracked and broken curb and sidewalk
- 9 delineate around work and staging areas. At all times keep a well-marked path for students and staff.

Sincerely,

Jeff Hill



City of Puyallup

---

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Engineering Tech IV  
Jhill@PuyallupWA.gov  
(253) 841-5424