



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Feb 23, 2023                      **Inspection Result:**     **NOT READY**

**Permit Number:** PRCA20220580

**Property Address:** 815 21ST ST SE, PUYALLUP, WA 98372;

**Contractor:** J & C BERGMAN CONTRACTING P.O. BOX 732091 PUYALLUP, WA 98373 Jake Bergman PO BOX 732091 PUYALLUP, WA 98373 (253) 961-0602

**To construct:** Minor interior TI & Adding 1771 SF to the existing office building  
REVISION (1) - 2/23/2023 - MECHANICAL DESIGN ADJUSTMENT

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

1. complete sole plate nailing per city approved plans
2. strap all beams and plates as discussed with contractor
3. provide energy paper work at time of next inspection
4. provide approved revision for MECH platform at time of next inspection
5. provide blocks at wall where trusses bear as discussed with contractor
6. provide bearing at girder truss Ho3 4 locations
7. provide letter from engineer of record on clarification of detail 4 on page S 1.2
8. plumbing approved
9. not ready

Sincerely,

Kevin Spruell  
Building Inspector I  
KSpruell@PuyallupWA.gov



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

(253) 841-5590