



Serenity Air Inc
201 W Stewart Ave
Puyallup WA 98371

info@serenityairinc.com
serenityairinc.com

Provide scope of work to include required weight of the economizer to determine structural analysis would not be required with all equipment identified. Provide verification the new economizer will not decrease the total economizer capacity of the existing unit which would meet 2018 WSEC requirement for replacement of existing system.

SCOPE OF WORK

We will be replacing a roof top package unit weighing 613lbs for a smaller roof top unit weighing 482lbs. This will be placed in the same location as the unit being removed and will not require an engineer to approve the roof stability for the lesser tonnage of the replacement unit. The unit will be placed on the existing curb with an adapter curb as required by local building codes. We will only be replacing one roof top unit.

All measurements for the installation have been submitted, as well as the Site Plan and images of the location of the package unit being replaced. The location address is listed below.

Rod's All-Star Auto
1632 River Road Puyallup WA 98371