

SUBMITTAL

Micrometl

DATE:

4/17

SUBMITTED TO:

COMPANY:

MicroMetl

DRAWN BY:

ABC

JOB NAME:


WEIGHT:

83lbs.

NOTES:

NOTES:

1. FILTER RACKS SUPPLIED WITH ECONOMIZER.
2. FILTERS ARE FIELD SUPPLIED
3. FOR HEAT PUMP APPLICATIONS A FIELD SUPPLIED AND INSTALLED 24VAC - SPST NORMALLY OPEN RELAY WILL BE NEEDED.
4. IF PURCHASED THROUGH MICROMETL YOU'LL NEED
(1) RELAY - 9901-5030
(4) WIRE LEADS - 9901-0134



MicroMetl Corporation certifies that the models GR1 and NS1 shown herein are licensed to bear the AMCA Seal.

The ratings shown are based on tests and procedures performed in accordance with AMCA Publication 511 and comply with requirements of the AMCA Certified Ratings Programs. The AMCA Certified Ratings Seal applies to Air Leakage and Air Performance ratings.

NOTE:

Economizer - Ultra Low Leak Economizer, Convertible Orientation, Belimo Zip - Single/Multiple Speed Electromechanical, Adjustable Dry Bulb or Enthalpy, Belimo Actuator, Painted Rain Hood With Aluminum Filter, Barometric Relief, All Necessary Panels and Hardware Included

PART NUMBER:

ECC-IMP2*CA-D**B

FILTER RACK

FIELD SUPPLIED FILTER

R/A DAMPER

BAROMETRIC RELIEF HOOD

HINGED O/A ASSEMBLY

ALLOW FOR 36IN. OF CLEARANCE


ECC-IMP2SCA-DB ECONOMIZER IS SHOWN ABOVE**

THE APPROVED CONSTRUCTION PLANS, DOCUMENTS AND ALL ENGINEERING MUST BE POSTED ON THE JOB AT ALL INSPECTIONS IN A VISIBLE AND READILY ACCESSIBLE LOCATION.

FULL SIZED LEDGIBLE COLOR PLANS ARE REQUIRED TO BE PROVIDED BY THE PERMITEE ON SITE FOR INSPECTION





HORIZONTAL ORIENTATION



Approved by: _____
Date: _____

Openings and dimensions may vary from contract. An order constitutes acceptance of these variances

VERTICAL ORIENTATION



MMC PART #	# OF FILTERS	WEIGHT
ECC-IMP2SCA-Dxxx	(1) 25" x 16" x 2" OR (1) 25" x 16" x 2"	83 LBS.
ECC-IMP2LCA-Dxxx	(1) 20" x 18" x 1" & (1) 18" x 18" x 1" OR (1) 20" x 18" x 2" & (1) 18" x 18" x 2"	92 LBS.