



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jul 12, 2023

Inspection Result: NOT READY

Permit Number: PRCA20220580

Property Address: 815 21ST ST SE, PUYALLUP, WA 98372;

Contractor: J & C BERGMAN CONTRACTING P.O. BOX 732091 PUYALLUP, WA 98373 Jake Bergman PO BOX 732091 PUYALLUP, WA 98373 (253) 961-0602

To construct: Minor interior TI & Adding 1771 SF to the existing office building
REVISION (1) - 2/23/2023 - MECHANICAL DESIGN ADJUSTMENT

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 3 1. this inspection is for phase 2
2. provide poly seal as discussed with contractor
3. provide positive connection at all plate breaks ,wall tie ins and tie in to existing building
4. provide clarification from architect on interior door hts per city approved plans
5. provide electrical cover approval at time of next inspection
6. provide attic access by final
7. plumbing approved

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org