



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jul 25, 2023

Inspection Result: **FAILED**

Permit Number: PRCA20220580

Property Address: 815 21ST ST SE, PUYALLUP, WA 98372;

Contractor: J & C BERGMAN CONTRACTING P.O. BOX 732091 PUYALLUP, WA 98373 Jake Bergman PO BOX 732091 PUYALLUP, WA 98373 (253) 961-0602

To construct: Minor interior TI & Adding 1771 SF to the existing office building
REVISION (1) - 2/23/2023 - MECHANICAL DESIGN ADJUSTMENT

On this day we have inspected your construction for **Water Service Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Please reschedule once pvc has been replaced with brass. See city standard detail 03.04.01

Corrections:

Sincerely,

Jason Little



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Engineering Tech IV
JLittle@PuyallupWA.gov
(253) 435-3636