



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Aug 01, 2023

Inspection Result: PARTIAL PASS

Permit Number: PRCA20220580

Property Address: 815 21ST ST SE, PUYALLUP, WA 98372;

Contractor: J & C BERGMAN CONTRACTING P.O. BOX 732091 PUYALLUP, WA 98373 Jake Bergman PO BOX 732091 PUYALLUP, WA 98373 (253) 961-0602

To construct: Minor interior TI & Adding 1771 SF to the existing office building
REVISION (1) - 2/23/2023 - MECHANICAL DESIGN ADJUSTMENT

On this day we have inspected your construction for **Water Service Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Okay to backfill.

Need certification for double check prior to final.

Schedule another inspection when completed.

Corrections:

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Jason Little

Engineering Tech IV

JLittle@PuyallupWA.gov

(253) 435-3636