



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Sep 19, 2023

**Inspection Result:** **FAILED**

**Permit Number:** PRRPM20231239

**Property Address:** 2014 37TH ST SE, PUYALLUP, WA 98372;

**Contractor:**

**To construct:** Replace Water Heater

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 ; provide Carbon monoxide alarm outside of bedrooms in hall at basement ,1st , and 2nd floor as discussed with homeowner.

Sincerely,

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684