

Emily Mallott

From: Janelle Montgomery
Sent: Tuesday, September 19, 2023 1:49 PM
To: Trevor Kelley
Cc: DPS Permit Center
Subject: FW: PRPL20231215 - Hot water heater replacement



Importance: High

Categories: Emily

SEE EMAIL RESPONSE IN
RED DUE TO MINIMAL
INFORMATION ON PLANS

Trevor,

I did not receive your response so had to fail the review. You will need to contact the Permit Center at (253) 864-4165 option 1 to have the email uploaded to be part of the permit package.

DPS,

The \$180 fee can be waived and once it is uploaded and processed I can complete my review. Please contact me if you have any questions.

Thank you,

Janelle Montgomery
 City of Puyallup | Senior Plans Examiner
 333 S Meridian | Puyallup, WA 98371
 Tel: (253) 770-3328
JMontgomery@puyallupwa.gov

CITY HALL IS NOW OPEN. PERMIT CENTER HOURS ARE 9AM-3:00PM

Did you know that you can easily submit for a permit online? Introducing CityView, our new online permitting system. Go to the [City's website page here](#) for more information. Or, scan this QR code with your phone to learn more.



Check permit status, schedule inspections and pay online at <https://secure.puyallupwa.gov>
Permit inquiries @ PermitCenter@puyallupwa.gov or contact (253) 864-4165 option 1.

From: Trevor Kelley <t.kelley@stopinc.com>
Sent: Monday, September 18, 2023 7:19 AM
To: Janelle Montgomery <JMontgomery@puyallupwa.gov>
Subject: RE: PRPL20231215 - Hot water heater replacement
Importance: High

CAUTION: This is an External Email. Do not click links or open attachments unless you are expecting them.

Hey Janelle,

Please see the responses below.

For the fastest response, please reply all with any questions and approvals you may have.



Trevor Kelley General Manager

STOP Inc

P: 877-380-7904 C: 253-394-6573

A: PO Box 111616 Tacoma, WA 98411

E: t.kelley@stopinc.com

Dispatch: info@stopinc.com

From: Janelle Montgomery <JMontgomery@puyallupwa.gov>
Sent: Tuesday, September 12, 2023 2:17 PM
To: Trevor Kelley <t.kelley@stopinc.com>
Subject: PRPL20231215 - Hot water heater replacement

Trevor,

To help expedite this review please respond to the following questions to assure was installed per 2018 IPC. Once I receive a response I will complete the review.

Confirm like for like water heater and gas line was adequate for 275,000 Btuh change out with no changes and installed in same location since received no floor plan. **The water heater is like for like with the same BTU. No alterations were made to the plumbing system.**

Confirm it was installed with all seismic straps required per code for seismic D. **Earthquake straps were installed per local code.**

Confirm expansion tank was installed as none shown with water heater manufacture's specification. **The heater does have an expansion tank per local code requirements.**

Thank you,

Janelle Montgomery
City of Puyallup | Senior Plans Examiner