



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Oct 10, 2023

**Inspection Result:** NOT READY

**Permit Number:** PRCA20220580

**Property Address:** 815 21ST ST SE, PUYALLUP, WA 98372;

**Contractor:** J & C BERGMAN CONTRACTING P.O. BOX 732091 PUYALLUP, WA 98373 Jake Bergman PO BOX 732091 PUYALLUP, WA 98373 (253) 961-0602

**To construct:** Minor interior TI & Adding 1771 SF to the existing office building  
REVISION (1) - 2/23/2023 - MECHANICAL DESIGN ADJUSTMENT

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 2 FINAL INSPECTION ON ADMIN OFFICE
  1. provide exit signage as discussed with contractor
  2. provide correct hardware and door signage at required exit doors as discussed with contractor
  3. provide insulation at attic access

Sincerely,

Kevin Spruell  
Building Inspector I  
KSpruell@PuyallupWA.gov  
(253) 841-5590